



AHMEDABAD MUNICIPAL CORPORATION
MAHANAGAR SEVA SADAN
CENTRAL LABORATORY
(An ISO 9001: 2015 Accredited Laboratory)



Lic No QAC/R91/4650

Dudheshwar Water Works Compound, Dudheshwar, Ahmedabad-380 004, Gujarat, India.
E-mail: centrallab@ahmedabadcity.gov.in, Phone No-(079) 25631105, 25630438.

To,
The Principal,
D.A.V International School
F.P. 3 & 6; T.P. 84-B, Off. Prahladnagar Corporate Road
Makarba, Ahmedabad

January 22, 2020.

Dear Sir,


We have analyzed your water sample collected on Dt. 17-01-2020 for the following Chemical and Bacteriological parameters. The analysis report is as hereunder.

Sr. No.	Parameter	Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source	Sample Value
		As per IS-10500-2012		
(1)	(2)	(3)	(4)	(5)
A. Organoleptic and Physical Parameters				
1	Colour, Hazen units, Max	5	15	0.1
2	pH value	6.5-8.5	No relaxation	7.59
3	Turbidity, NTU, Max	1	5	0.2
4	Total dissolved solids, mg/l, Max	500	2000	242
B. General Parameters				
1	Total hardness (as CaCO ₃), mg/l, Max	200	600	80
2	Calcium (as Ca), mg/l, Max	75	200	16
3	Magnesium (as Mg), mg/l, Max	30	100	9.76
4	Chloride (as Cl), mg/l, Max	250	1000	70
5	Sulphate (as SO ₄) mg/l, Max	200	400	15.2
6	Total alkalinity as calcium carbonate, mg/l, Max	200	600	70
7	Free residual chlorine, mg/l, Min	0.2	1	Nil
C. Bacteriological Quality of Drinking Water				
1	Total Coliform bacteria, MPN/100 ml.	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	Not Detected
2	E. coli, MPN/100 ml.	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	Not Detected

Remarks:

1. The Central Laboratory, AMC, has collected the sample.
2. The result contained in this report relate only to the sample material tested.
3. The report is not being reproduce wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertising media without our special permission in writing.

NOTE — It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned under 'acceptable' render the water not suitable, but still 'permissible limit in the absence of alternate source' in column 4, above which the sources will have to be rejected. May be tolerated in the absence of an alternative source but up to the limits indicated


Dr. H. C. Mandalia
Scientist In-Charge