

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

To,

Principal DAV International School
Verka Chowk;By-Pass Road,Amritsar


No.: RWTLASR/2324/00691 Dated : 06/02/2024

Subject : . Testing Reports of Water Samples.

Reference: Your Letter/SRF No. SPL/Safety/2024 Dated: 19/01/2024

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 25/01/2024. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Amritsar

D/A : Test Report


Authorized Signatory
For, Regional Water Testing Lab
Amritsar

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

TEST REPORT

Name & Address of Customer : Principal DAV International School Verka Chowk, By-Pass Road, Amritsar	Customer Reference No.	No : SPL/Safety/2024 Dated : 19/01/2024
	Sample Submitted by	Mr.Sunil
	Date of Sample Receipt	25/01/2024
	Analysis Starting Date	25/01/2024
	Analysis completion Date	27/01/2024

Discipline : Chemical Testing		Group: Water	
ULR No.:	TC98152400000027F	Sample Type :	Water
Test Report No.:	RWTLASR/2324/00691	Date of Issue :	06/02/2024
Registration no.:	RWTLASR/REG2324/06377	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	By Pass Road(S/pump 300 ft) / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Amritsar
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.63@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	TDS	330	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
5	Turbidity	0.40@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
6	Alkalinity	380	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
7	Hardness	312	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2019) EDTA Method
8	Calcium	52.90	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	43.74	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	13.99	250	1000	mg/l	IS 3025 (Part:32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

- The results apply to the sample as received only.
- The sample will be destroyed after retention time unless otherwise specified specially.
- This report is not to be reproduce wholly or in part and can't beused be as evidence in court of law.
- Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
- * Value not available or test not performed for this parameter.
- Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Mr. Pankaj Kumar
Quality Manager
Authorized Signatory
For,Regional Water Testing Lab
Amritsar



mohmcasr@gmail.com

ਨੰ: ਐਚ/੨੨




ਦਫਤਰ ਸਿਹਤ ਵਿਭਾਗ ਨਗਰ ਨਿਗਮ, ਅੰਮ੍ਰਿਤਸਰ।

ਮਿਤੀ/ 23/4/24

Subject: No Objection Certificate

DAV INTERNATIONAL SCHOOL VERKA CHOWK, BY-PASS ROAD, AMRITSAR ਮਿਤੀ 23/04/2024 ਦੇ ਸਬੰਧ ਵਿਚ ਸੈਨੇਟਰੀ ਇੰਸਪੈਕਟਰ/ਚੀਫ ਸੈਨੇਟਰੀ ਇੰਸਪੈਕਟਰ ਦੀ ਰਿਪੋਰਟ ਮੁਤਾਬਕ ਮੇਕੇ ਉਪਰ DAV INTERNATIONAL SCHOOL, AMRITSAR ਸੈਨੀਟੇਸ਼ਨ ਦੇ ਲਿਹਾਜ਼ ਨਾਲ ਵਧੀਆ ਹੈ। ਇਸ ਲਈ ਸਾਲ 2024-2025 ਲਈ ਇਤਰਾਜ਼ਹੀਣਤਾ ਸਰਟੀਫਿਕੇਟ ਦਿੱਤਾ ਜਾਂਦਾ ਹੈ।


ਸਿਹਤ ਅਫਸਰ
ਨਗਰ ਨਿਗਮ, ਅੰਮ੍ਰਿਤਸਰ।